



# SHRIRAM INSTITUTE FOR INDUSTRIAL RESEARCH

(A Unit of Shriram Scientific and Industrial Research Foundation)

## TEST CERTIFICATE

19, University Road, Delhi-110007

Telephone: 91-011-27667267, 27667983, 27667860

Fax: 91-011-27667676, 27667207 E.mail: sridlhi@vsnl.com.

Visit us at [Http://www.shriraminstitute.org](http://www.shriraminstitute.org)

ISO-9001 Certified Institute

000082278

**Issued to :**

YEEKAY TECHNOCRAT PVT. LTD.

101-C, (GR. FLOOR),

KUNDAN HOUSE,

HARI NAGAR ASHRAM, (BEHIND NAFED BUILDING)

NEW DELHI - 110014

Kind Attn: UJJAWAL KUMAR, -

**Sample Particulars :**

One sample described as PPR-pipes & fittings brand name "FUSION", PPR-C polypropylene random copolymer & material used VESTOLIN P 9421 (DSM Germany), 40 mm dia, was received.

(Supplementary report of report No. 81689 dated 17.06.2004)

J.O.No. 406-141-1217

Reg.No. 1129367

Date 24-06-2004

GC-01 (REV-03)

Your Ref.No. -

Date 11.06.2004

## TEST RESULTS

(As per IS: 9845-198)

<u>S.No.</u>	<u>Test</u>	<u>Result</u> <u>Obtained</u>	<u>Requirement as per</u> <u>IS: 10910-1984</u>	<u>Conformity</u>
1.	Migration test Extractive residue with:			
a)	Distilled water at 121°C for 2 hours, mg/l	18	60 Maximum	Yes
	mg/dm <sup>2</sup>	1.8	10 Maximum	Yes
b)	Distilled water at 100°C for 2 hours, mg/l	14	60 Maximum	Yes
	mg/dm <sup>2</sup>	1.4	10 Maximum	Yes
c)	Distilled water at 40°C for 10 days, mg/l	22	60 Maximum	Yes
	mg/dm <sup>2</sup>	2.2	10 Maximum	Yes

\*\*\*\*\*

DOR: 11.06.2004

DOC: 24.06.2004

AUTHORISED SIGNATORY

By: Director/AD-Test

Sr.Scientist/Signature

NOTE 1. The result listed refer only to the tested sample(s) and applicable parameter(s). Endorsement of products is neither inferred nor implied.

2. Total liability of our Institute is limited to the invoiced amount.

3. Samples will be destroyed one month from the date of issue of test certificate unless otherwise specified.

4. This report is not to be reproduced wholly or in part and cannot be used as an evidence in any Court of law, unless

